





SUMMARY REPORT

DC13305-026

REPORT ON TESTING OF DUNLOP PRO RAPID WATERPROOFING MEMBRANE TO THE REQUIREMENTS OF AS/NZS 4858:2004

CLIENT

Ardex Australia Pty Ltd 20 Powers Road Seven Hills NSW 2147 AUSTRALIA

BRANZ

REPORT NUMBER: **DC13305-026**

ISSUE DATE: **22 April 2021**

REVIEW DATE: **22 April 2026**

PAGE:

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT. EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.

TEST SUMMARY

Objective

Testing was completed to the requirements of AS/NZS 4858:2004 Wet Area Membranes.

Summary

Passing results were obtained for the 0.52 mm thick Dunlop Pro Rapid Waterproofing membrane where requirements are stated in the AS/NZS 4858:2004 Standard. The Dunlop Pro Rapid Waterproofing membrane samples supplied met the requirements to be classified as Class III (High Extensibility).

Test sponsor

Ardex Australia Pty Ltd 20 Powers Road Seven Hills NSW 2147 AUSTRALIA

Description of test specimen

The client supplied sheet membrane samples to be tested. The samples were assigned the BRANZ Sample Reference 21/043.

Date of test

Testing completed on 13 April 2021.

LIMITATION

The results reported here relate only to the item/s tested.

TERMS AND CONDITIONS

This report is issued in accordance with the Terms and Conditions as detailed and agreed in the BRANZ Services Agreement for this work.

SIGNATORIES



Author

Holly Moody Materials Technician BRANZ



Konrad Suschke Materials Scientist BRANZ

DOCUMENT REVISION STATUS

ISSUE NO.	DATE ISSUED	DESCRIPTION
1	22 April 2021	Initial Issue
2		