





SUMMARY REPORT

DC13305-014

SUMMARY ON TESTING OF DUNLOP UNDERTILE WATERPROOFING MEMBRANE TO THE REQUIREMENTS OF AS/NZS 4858:2004

CLIENT

Ardex Australia Pty Ltd 20 Powers Road Seven Hills NSW 2147 AUSTRALIA

BRANZ

REPORT NUMBER: **DC13305-014**

ISSUE DATE:

REVIEW DATE:

PAGE:

16 April 2021

TEST SUMMARY

Objective

Testing was completed to the requirements of AS/NZS 4858:2004 Wet Area Membranes.

Summary

Passing results were obtained for the 0.61 mm thick Dunlop Undertile Waterproofing membrane where requirements are stated in the AS/NZS 4858:2004 Standard. The Dunlop Undertile Waterproofing membrane samples supplied met the requirements to be classified as Class III (High Extensibility).

Test sponsor

Ardex Australia Pty Ltd 20 Powers Road Seven Hills NSW 2147 AUSTRALIA

Description of test specimen

The client supplied sheet membrane samples to be tested. The samples were assigned the BRANZ Sample Reference 21/040.

Date of test

Testing completed on 13 April 2021.

LIMITATION

The results reported here relate only to the item/s tested.

TERMS AND CONDITIONS

This report is issued in accordance with the Terms and Conditions as detailed and agreed in the BRANZ Services Agreement for this work.

SIGNATORIES



Author

Holly Moody Materials Technician BRANZ



Reviewer

Konrad Suschke Materials Scientist BRANZ

DOCUMENT REVISION STATUS

ISSUE NO.	DATE ISSUED	DESCRIPTION
1	16 April 2021	Initial Issue
2		