



**BRANZ**

1222 Moonshine Road  
Judgeford RD1  
Porirua 5381  
New Zealand  
T +64 4 237 1170  
F +64 4 237 1171  
branz@branz.co.nz  
www.branz.co.nz



# SUMMARY REPORT

## DC13305-015-02

### SUMMARY ON TESTING OF DUNLOP UNDERTILE WATERPROOFING MEMBRANE TO THE REQUIREMENTS OF AS 4654.1-2012

**CLIENT**

Ardex Australia Pty Ltd  
20 Powers Road  
Seven Hills  
NSW 2147  
AUSTRALIA



PROJECT NUMBER:

**DC13305**

ISSUE DATE:

**12 July 2021**

REVIEW DATE:

**12 July 2026**

PAGE:

**1 of 3**

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT. EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.

# TEST SUMMARY

## Objective

Testing was completed of the Dunlop Undertile Waterproofing membrane to the requirements of AS 4654.1-2012 *Waterproofing membranes for external above-ground use Part 1: Materials*.

## Summary

Passing results were obtained for the 2.10 mm thick Dunlop Undertile Waterproofing membrane where requirements are stated in the AS 4654.1-2012 Standard. The Ardex Dunlop Undertile Waterproofing membrane samples supplied met the requirements to be classified as Class III (High Extensibility).

## Test sponsor

Ardex Australia Pty Ltd  
20 Powers Road  
Seven Hills  
NSW 2147  
AUSTRALIA

## Description of test specimen

The client supplied sheet membrane samples to be tested. The samples were assigned the BRANZ sample reference 21/040 and 21/456.

## Date of test

Testing completed on 30 June 2021.

# LIMITATION

The results reported here relate only to the items tested.

# TERMS AND CONDITIONS

This report is issued in accordance with the Terms and Conditions as detailed and agreed in the BRANZ Services Agreement for this work.



REPORT NUMBER:

**DC13305-015-02**

ISSUE DATE:

**12 July 2021**

PAGE:

**2 of 3**

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT.  
EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.

# SIGNATORIES



## Author

Holly Moody  
Materials Technician  
BRANZ



## Reviewer

Konrad Suschke  
Materials Scientist  
BRANZ

# DOCUMENT REVISION STATUS

ISSUE NO.	DATE ISSUED	DESCRIPTION
1	16 April 2021	Initial Issue
2	12 July 2021	Report variation, new control, cyclic and heat ageing results



REPORT NUMBER:

**DC13305-015-02**

ISSUE DATE:

**12 July 2021**

PAGE:

**3 of 3**

THE LEGAL VALIDITY OF THIS REPORT CAN ONLY BE CLAIMED ON PRESENTATION OF THE COMPLETE SIGNED PAPER REPORT. EXTRACTS OR ABRIDGMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.